



Fire Department Connection (FDC) Signage Requirements

Fire Department Connection Signage - Approval

All Fire Department Connection signs shall be reviewed and approved by the Fire Prevention Bureau prior to purchase to ensure the correct description of the protection systems and coverage area(s).

Fire Department Connection Signage

Fire Department Connection (FDC) signs shall be at least twelve (12) inches wide and eighteen (18) inches high. Signs shall be a street sign type with reflective white background and letters and borders in red. Signs shall be permanently affixed to a stationary post and installed approximately six (6') feet and six (6") inches above the finished grade at the FDC. Signs may be installed on permanent buildings or walls at the height listed above.

- Address or Address Ranges of the property('s) that is protected
FDC Operating Pressure: Provide the operating pressure required at the FDC inlets.
- Due to some areas with grade changes and landscaping additional directional signage may be required.

Signage Description

- FDC – Identifies the Fire Department Connection
- 1 of 1 – Identifies that this is FDC #1 of a total of 1 FDCs for the identified property. If 2 FDC exist, they would be listed 1 of 2 and 2 of 2.

Signage Design and Layout

- Background: White Reflective
- Font: Arial
- Color: Red
- Border: Red – Size
- Size
 - 1" Margin with ¼" Border within the Margin, around entire sign
 - ½" - Blank Space
 - FDC – 3" - Red, Bold, Arial Font
 - Number of FDCs for Building – 1" - Red, Bold, Arial Font



- ½" - Blank Space
- Address of Building – 2.5" - Red, Bold, Arial Font
- ½" - Blank Space
- FDC Operating Pressure – 1" - Red, Bold, Arial Font, FDC Operating Pressure-Underlined
- ½" - Blank Space



FDC

1 of 1

6620 - 6630

Mooney Street

FDC Operating Pressure: 150psi.



FDC

